

TABLE 1
OAR 340-071-0220
MINIMUM SEPARATION DISTANCES

Items Requiring Setback	From Subsurface Absorption Area Including Replacement Area	From Septic Tank and Other Treatment Units, Effluent Sewer and Distribution Units
1. Groundwater Supplies and Wells.	*100'	50'
2. Springs:		
• Upgradient.	50'	50'
• Downgradient.	100'	50'
**3. Surface Public Waters:		
• Year round.	100'	50'
• Seasonal.	50'	50'
4. Intermittent Streams:		
• Piped (watertight not less than 20' from any part of the onsite system).	20'	20'
• Unpiped.	50'	50'
5. Groundwater Interceptors:		
• On a slope of 3% or less.	20'	10'
• On a slope greater than 3%:		
• Upgradient.	10'	5'
• Downgradient.	50'	10'
6. Irrigation Canals:		
• Lined (watertight canal).	25'	25'
• Unlined:		
• Upgradient.	25'	25'
• Downgradient.	50'	50'
7. Manmade Cuts Down Gradient in Excess of 30 Inches (top of downslope cut):		
• Which Intersect Layers that Limit Effective Soil Depth Within 48 Inches of Surface.	50'	25'
• Which Do Not Intersect Layers that Limit Effective Soil Depth.	25'	10'
8. Downgradient Escarpments:		
• Which Intersect Layers that Limit Effective Soil Depth.	50'	10'
• Which Do Not Intersect Layers that Limit Effective Soil Depth.	25'	10'
9. Property Lines.	10'	5'
10. Water Lines.	10'	10'
11. Foundation Lines of any Building, Including Garages and Out Buildings.	10'	5'
12. Underground Utilities.	10'	—

* 50-foot setback for wells constructed with special standards granted by WRD.

**This does not prevent stream crossings of pressure effluent sewers.